



Dominion

DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC

INSPECTION DATE: 02/09/15

WEATHER: LIGHT RAIN; LIGHT WIND; 39°F

INSPECTED BY: JEFF MARCUM / SEAN TEMENGER

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	NO STANDING WATER BEHIND SAND BAGS - AREA DRY
Erosion	N	N	REP-REP & SANDBAGS IN GOOD CONDITION
Low Point, B dike*			
Flow	N	N	NO STANDING WATER - AREA DRY
Erosion	N	N	REP-REP & SANDBAGS IN GOOD CONDITION
Outfall water surface El. (top of stoplogs to water)			63.5"; NO STANDING WATER; NO SEEP AT TOP IN NINE GAUGES; JUST SMALL SLOW DIPS AT BOTTOM IN NW CORNER

* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.): ROADS DRY, BUT SOFT; NO SIGNIFICANT RAIN B/Y INSPECTION

LOW TIDE 16:13

